

Certificate

No. c6650a-21

Customer:

Ma-Fia s.r.o.
Scheinerova 65
628 00 Brno, Czech republic

Class D

Test sample(s):

Data Cable:
WIREX Installation Cable CAT5E FTP LSOH/DCA 305m box violet
Part-no.: WIC-5-FU-LD-30-VI

Patch Panel:
WIREX 19" Patch panel CAT5E STP 24xRJ45 1U cable management holder black
Part-no.: WPP-5-S-24-1-BL

Outlet:
WIREX Keystone CAT5E STP toolless silver
Part-no.: WKE-5-S-TL-SI

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class D

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report **no. R6650a-21** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 25.06.2021



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



*Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate D-PL-17559-01-00.*

GHMT AG

In der Kolling 320
66450 Bexbach / Germany

PO box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**